



## Proposed Code Change

State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

### FOR OFFICE USE ONLY

Received

Code

#### INSTRUCTIONS:

*Only TYPED copy accepted.*

*(KEY – Dashed line through material to be deleted, underline material to be added)*

*Use second sheet for any material requiring more space.*

Code Title International Residential Code		Edition 2009
Section number and title SECTION R315 CARBON MONOXIDE ALARMS		Page 63
Proponent Ben Shirk	Title Estimator	
Address 63341 CR 33, Goshen IN 46528		Phone 574-642-4326
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input checked="" type="checkbox"/> Delete without substitution		
<b>Delete without substitution</b>		
REASON AND FISCAL IMPACT		
<p>Current CO detectors do not warn of long term nor low level CO exposure. Safety is better served by annual inspections of heating &amp; other combustion appliances.</p> <p>In our area most new homes use sealed combustion furnaces with no possibility of CO exposure from the heating system.</p> <p>No fiscal impact.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		